



Shanker Laboratories

F-277, Flatted Factory Complex, Captain Gaur Marg,
(Near Okhla NSIC Metro Station), Okhla, New Delhi - 110020

Known for Excellency in Testing

TEST REPORT

Dated: December 2, 2023

Report No: 29173

Source: M/s Chandra Arya Vidya Mandir ,C-Block ,East of Kailash,110065

Nature of Sample: Said to be Water

Sample ID: Drinking Water

Dt. of Receipt: 30.11.2023

Laboratory Mark: SL 29173

Test period: 30 Nov-2 Dec. 2023

S. No	Parameter	Results	Test Method	Acceptable Limits as per IS: 10500-2012
1	Colour Hz	1	3025-Pt 4	Not more than 5Hz
2	Odour	Agreeable	3025-Pt 5	Agreeable
3	Turbidity NTU	Nil	3025-Pt 10	Not more than 1
4	Iron Fe mg/L	BDL (DL 0.01mg/L)	3025-Pt 53	Not more than 1 mg/L
5	E Coli	Absent	1622	Absent
6	Total Coliform	Absent	1622	Absent

Remarks: The Water sample conforms to the above specifications of IS 10500.

BDL: Below detection limit. DL: Detection limit.

Conditions:

1. Results given above refer only to the sample supplied.
2. The report is being issued on the specific understanding that Shanker Laboratories will not in any way be involved in any action following the interpretation of the above results.
3. This report shall not be reproduced, except in full, without the written permission of CEO, Shanker Laboratories, New Delhi.


Esha
Analyst


Neeraj Katyal
Authorised Signatory

---- End of Report ----

NABL Accredited (TC-6113). MSME Reg. No. DL08D0002143

Phones : 9999993311, 9999990481, 9999552799, 9811505398

Email : shankerlaboratories@gmail.com

Website : www.shankerlaboratories.com



Shanker Laboratories

F-277, Flatted Factory Complex, Captain Gaur Marg,
(Near Okhla NSIC Metro Station), Okhla, New Delhi - 110020

Known for Excellency in Testing



TEST REPORT

Dated: December 2, 2023

Report No: 29173

Source: M/s Chandra Arya Vidya Mandir ,C-Block ,East of Kailash,110065

Nature of Sample: Said to be Water

Sample ID: Drinking Water

Dt. of Receipt: 30.11.2023

Laboratory Mark: SL 29173

Test period: 30 Nov-2 Dec. 2023

S. No	Parameter	Results	Test Method	Acceptable Limits as per IS: 10500-2012
1	pH	8.02	3025-Pt 11	6.5-8.5
2	Total Hardness as CaCO ₃ mg/L	143	3025-Pt 21	Not more than 200 mg/L
3	Calcium Ca mg/L	40.80	3025-Pt 40	Not more than 75 mg/L
4	Magnesium Mg mg/L	9.84	3025-Pt 46	Not more than 30 mg/L
5	Total Alkalinity CaCO ₃ mg/L	94	3025-Pt 23	Not more than 200 mg/L
6	Total Dissolved Salts TDS (mg/L)	202	3025-Pt 16	Not more than 500 mg/L
7	Chloride Cl mg/L	11.91	3025-Pt 32	Not more than 250 mg/L
8	Sulphate SO ₄ mg/L	57.26	3025-Pt 24	Not more than 200 mg/L

Remarks: The Water sample conforms to the above specifications of IS 10500.

Conditions:

1. Results given above refer only to the sample supplied.
2. The report is being issued on the specific understanding that Shanker Laboratories will not in any way be involved in any action following the interpretation of the above results.
3. This report shall not be reproduced, except in full, without the written permission of CEO, Shanker Laboratories, New Delhi..

Esha

Esha
Analyst

Neeraj

Neeraj Katyal
Authorised Signatory

---- End of Report ----

NABL Accredited (TC-6113). MSME Reg. No. DL08D0002143

Phones : 9999993311, 9999990481, 9999552799, 9811505398

Email : shankerlaboratories@gmail.com

Website : www.shankerlaboratories.com